

RIFERIMENTI	
SOCIETA': SIPEA SRL	
CODICE STABILIMENTO: LTC1	
RIVAROLO CANAVESE (TO) Corso Indipendenza, 53	

CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/03/11							
CODICE	CO R 021	COT R 057	NOX NO2 R 027	SO2 R 026	PLV R 022	TF 051	QFS 055
CAMPO SCALA	0-500 mg/Nm3	0-60 mg/Nm3	0-600 mg/Nm3	0-400 mg/Nm3	0-60 mg/Nm3	0-300 -C	0-54263 Nm3/h
LIMITE GIORNALIERO	150 mg/Nm3		300 mg/Nm3				
VALORE MIN-MAX	0.1-102.6	0.0-1.1	76.0-184.1	0.0-0.1	0.0-0.0	138.5-144.6	30644.1-33644.4
MEDIA GIORNALIERA	33.5	0.3	111.4	0	0	141.3	31931.2
SUPERO LIMITE GIORNALIERO	NO	NO	NO	NO	NO	NO	NO

CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/03/11		
CODICE	CO R 021	TF051

CAMPO SCALA		
LIMITE GIORNALIERO		
VALORE MIN-MAX		
MEDIA GIORNALIERA		
SUPERO LIMITE GIORNALIERO		

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 