


RIFERIMENTI	
SOCIETA': SIPEA SRL	
CODICE STABILIMENTO: LTC1	
RIVAROLO CANAVESE (TO)	
Corso Indipendenza, 53	

CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/03/13							
CODICE	CO R 021	COT R 057	NOX NO2 R 027	SO2 R 026	PLV R 022	TF 051	QFS 055
CAMPO SCALA	0-500 mg/Nm3	0-60 mg/Nm3	0-600 mg/Nm3	0-400 mg/Nm3	0-60 mg/Nm3	0-300 -C	0-54263 Nm3/h
LIMITE GIORNALIERO	150 mg/Nm3		300 mg/Nm3				
VALORE MIN-MAX	17.8-70.6	0.0-1.3	77.7-125.6	0.0-0.1	0.0-0.0	140.6-145.6	31482.0-34333.9
MEDIA GIORNALIERA	37.3	0.2	96	0	0	143.3	32918.5
SUPERO LIMITE GIORNALIERO	NO	NO	NO	NO	NO	NO	NO

CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/03/13		
CODICE	CO R 021	TF051

CAMPO SCALA		
LIMITE GIORNALIERO		
VALORE MIN-MAX		
MEDIA GIORNALIERA		
SUPERO LIMITE GIORNALIERO		

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 