


RIFERIMENTI	
SOCIETA': SIPEA SRL	
CODICE STABILIMENTO: LTC1	
RIVAROLO CANAVESE (TO) Corso Indipendenza, 53	

CALDAIA BIOMASSA - EMISSIONI IMPIANTO DEL 2016/03/23							
CODICE	CO R 021	COT R 057	NOX NO2 R 027	SO2 R 026	PLV R 022	TF 051	QFS 055
CAMPO SCALA	0-500 mg/Nm3	0-60 mg/Nm3	0-600 mg/Nm3	0-400 mg/Nm3	0-60 mg/Nm3	0-300 -C	0-54263 Nm3/h
LIMITE GIORNALIERO	150 mg/Nm3		300 mg/Nm3				
VALORE MIN-MAX	11.6-166.7	0.0-3.6	71.8-133.8	0.0-3.7	0.0-0.2	143.9-151.0	22105.5-45584.8
MEDIA GIORNALIERA	69.1	1	93.4	0.2	0	147.9	38004.6
SUPERO LIMITE GIORNALIERO	NO	NO	NO	NO	NO	NO	NO

CALDAIA METANO - EMISSIONI IMPIANTO DEL 2016/03/23		
CODICE	CO R 021	TF051

CAMPO SCALA		
LIMITE GIORNALIERO		
VALORE MIN-MAX		
MEDIA GIORNALIERA		
SUPERO LIMITE GIORNALIERO		

DATI VERIFICATI DA: 

RESPONSABILE IMPIANTO: 